



## **ADDENDUM NOTICE NO. 1**

### **KWAMADLALA WATER PIPELINE & PUMPSTATION EMERGENCY SCHEME**

**CONTRACT UGU-07-1653-2023**

**CONSTRUCTION OF A 200MM DIAMETER X 8KM LONG STEEL & 200MM X 4KM LONG  
PVC-M CLASS 20 RISING MAIN FROM KWAMADLALA PUMPING STATION TO QWABE  
RESERVOIR. TWO NEW PUMP STATIONS AT DOMBA AND MADLALA**

### **EVALUATION CRITERIA**

With reference to the above-mentioned bid as advertised on **Thursday, 25 January 2024 SC HERALD**. Kindly note the Functionality Points were omitted on the Tender Document. Herewith is the attached Evaluation Criteria with Points. Please take note and attach same to the document on submission.

We apologise for the inconvenience caused.

**NTABISO MABASO:  
ACTING MANAGER:  
SUPPLY CHAIN MANAGEMENT**

**KWAMADLALA WATER PIPELINE & PUMPSTATION EMERGENCY SCHEME**

**CONTRACT UGU-07-1653-2023**

**CONSTRUCTION OF A 200MM DIAMETER X 4km LONG STEEL & 200MM X 8km LONG PVC-M CLASS 20 RISING MAIN FROM KWAMADLALA PUMPING STATION TO QWABE RESERVOIR, NEW PUMP STATIONS AT DOMBA AND MADLALA**

**ADDENDUM No 01: DATED 21 FEBRUARY 2024**

In accordance with clause F.3.2 of the Standard Conditions of Tender, bidders are hereby required to make the changes described hereunder (in black ink) in their tender documents. A signed copy of the addendum must be submitted with your bid.

Bidders are also required to acknowledge receipt of this addendum by return email to the Employer's Agent, for the attention of Mr Poobalan Govender to: [nokwanda.mzobe@ugu.gov.za](mailto:nokwanda.mzobe@ugu.gov.za) and [reception@pgaconsulting.co.za](mailto:reception@pgaconsulting.co.za).

**SECTION 1: TENDER DOCUMENT: EVALUATION OF TENDER OFFERS-SCORE CARD**

1.1 Notwithstanding anything to the contrary stated in the tender documents, and with reference to clause F.3.11 of the Standard Conditions of Tender, the procedure for evaluation of responsive tenders will be **Method 2: Functionality, Price, and Preference**, with the **80/20 Preference Point System**. All tenders will be evaluated in three (3) stages as follows:

- ❖ The first stage will be in terms of responsiveness (eg), attended compulsory site briefing; & or all returnables submitted.
- ❖ The second stage: only tenders that obtain a minimum score of **70 points (70%)** for functionality.
- ❖ The third stage: Price and Preference, above tenders will be assessed in accordance with the 80/20 preference point system in accordance with the Preferential Procurement Regulations, 2022 as described in the tender documents.

1.2 The scoring for functionality omitted in the tender will be carried out in the applicable areas and using the criteria and scoring presented in the tables below. The relevant supporting documents and schedules must be included in your tender for evaluation purposes.

Tenderers will be evaluated for functionality in the following key areas:

Description (Key Areas)	Maximum Allocated Points
Experience of Bidder with respect to similar projects	50
Experience of Key Personnel (Construction Manager/ Site Agent)	10
Experience of Key Personnel (Foreman)	10
Construction Methodology and Preliminary Programme	10
Financial Capacity	10
Machinery/Equipment Availability	10
<b>TOTAL MAXIMUM POINTS</b>	<b>100</b>

## SECTION 2: PREPARED CHANGE DOCUMENTS FOR INSERTION

For ease of making the above changes, kindly print and replace the pages attached. (8 pages enclosed).

Page	Part of Tender	Description of Amendment
TP7, TP8, TP9, TP10	T1: Tendering Procedures	Replace the tendering procedures pages with the attached document
RD2, RD3, RD4, RD5	T2: Returnable Documents	Replace the returnable documents selected pages with the attached ones

## SECTION 3: STEEL PIPES AND FITTINGS LININGS AND COATINGS

Corrosion protection of steel pipes and fittings of 200mm diameter and greater are to be lined and coated as detailed hereunder.

EXPOSURE CONDITIONS		Pipe internal		* refer to ISO 12944-2 edition 2017-11			
SUBSTRATE		New steel					
SURFACE PREPARATION		Sa 2.5		* refer to ISO 8501 -1 & 2 / SSPC VIS 4			
COATING SYSTEM							
COATING SYSTEM		Data Sheet	Volume Solids in %	Theoretical coverage at m <sup>2</sup> /ltr at DFT in µm	Film Thickness in µm		Minimum Interval between coats at 20 °C
Touch Up / Full Coat	Coating				Wet Film WFT	Dry Film DFT	
F.C.	SigmaGuard 720	7433	78	5.2	192	150	8 hours
F.C.	SigmaGuard 720	7433	78	5.2	192	150	8 hours
Total Dry Film Thickness in µm					300		

EXPOSURE CONDITIONS		Im4 (Pipe External)		* refer to ISO 12944-2 edition 2017-11																																															
SUBSTRATE		New steel																																																	
SURFACE PREPARATION		Sa 2.5		* refer to ISO 8501 -1 & 2 / SSPC VIS 4																																															
COATING SYSTEM																																																			
<table><tr><th colspan="2">COATING SYSTEM</th><th rowspan="2">Data Sheet</th><th rowspan="2">Volume Solids in %</th><th rowspan="2">Theoretical coverage at m<sup>2</sup>/ltr at DFT in µm</th><th colspan="2">Film Thickness in µm</th><th rowspan="2">Minimum Interval between coats at 20 °C</th></tr><tr><th>Touch Up / Full Coat</th><th>Coating</th><th>Wet Film WFT</th><th>Dry Film DFT</th></tr><tr><td>F.C.</td><td>SigmaCover 380</td><td>7979</td><td>80</td><td>5.3</td><td>188</td><td>150</td><td>8 hours</td></tr><tr><td>F.C.</td><td>SigmaCover 380</td><td>7979</td><td>80</td><td>5.3</td><td>188</td><td>150</td><td>8 hours</td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr><tr><td colspan="5">Total Dry Film Thickness in µm</td><td colspan="3">300</td></tr></table>								COATING SYSTEM		Data Sheet	Volume Solids in %	Theoretical coverage at m <sup>2</sup> /ltr at DFT in µm	Film Thickness in µm		Minimum Interval between coats at 20 °C	Touch Up / Full Coat	Coating	Wet Film WFT	Dry Film DFT	F.C.	SigmaCover 380	7979	80	5.3	188	150	8 hours	F.C.	SigmaCover 380	7979	80	5.3	188	150	8 hours									Total Dry Film Thickness in µm					300		
COATING SYSTEM		Data Sheet	Volume Solids in %	Theoretical coverage at m <sup>2</sup> /ltr at DFT in µm	Film Thickness in µm		Minimum Interval between coats at 20 °C																																												
Touch Up / Full Coat	Coating				Wet Film WFT	Dry Film DFT																																													
F.C.	SigmaCover 380	7979	80	5.3	188	150	8 hours																																												
F.C.	SigmaCover 380	7979	80	5.3	188	150	8 hours																																												
Total Dry Film Thickness in µm					300																																														

#### SECTION 4: ACKNOWLEDGEMENT OF ADDENDUM BY BIDDER

I/we hereby acknowledge receipt of Addendum No 01 to **Contract No Ugu-07-1653-2023**, which we will include in our bid.

*Signed on behalf of the bidder*

<b>Name of bidder:</b>		
<i>Date:</i>	<i>Signatory name:</i>	<i>Signature:</i>

**End**